



**NOTES :-**

- FUSE: FIG 1.1 PER CCT. (AER OR FPR)
- UNLESS OTHERWISE SPECIFIED ALL WIRING BEARING A COLOUR CODE TO BE 0.7mm. PLATE WIRING TO BE 0.5mm
- Ø FOR WIRING SEE ASS. COMMON SERVICES DIAGRAM.
- FOR TEST PURPOSES REMOVE STRAP 20-19 & CONNECT SUITABLE BATT. IN SERIES OPPOSITION TO LOWER BATT. VOLTAGE TO POS. BATT. LOW VOLTAGE LIMIT.
- PROVIDED AT GATEWAY INTERNATIONAL EXCHANGE.

REV	DATE	DEL	DC	ORDER	CKD	APD	CHANGE
7	13.3.64			12458			GRP FUSE ALARM FIG 4 DELETED FIG 6 REVISED.
6	31.1.62			48771			FIG 1A BATT TAG 1B WAS DELETED.
5	9.12.61			48628			FIG 6. WIRING OF RIB REVISED & KEY 'KAT' WAS DESIGNATED K.T.
4							FIG 6. ALM. TEST ADDED AND ASSOC. WIRING.
3							FUSING REVERSED FIG 1.
2							FIGS 1, 2 & 6 MINOR AMENDMENTS.
1							

**FUSE ALARM ARRANGEMENTS RINGER RACK**

DRN: T-EQPT CKD: ORIGIN: T-EQPT  
 TCD: APPD: STANDARD: ATW 22001  
 NZPO ENGINEER-IN-CHIEF, WELLINGTON.

SHT 1 OF 1  
 SIZE A2 **GBW 15340**